



**POLITECNICO**  
MILANO 1863

Laboratorio Prove Materiali - NB 1777 CPR

**Notified Body 1777 - CPR**

**CERTIFICATE OF CONSTANCY OF PERFORMANCE**  
**1777 - CPR - 21.02**

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

**Fluid Viscous Damper**

with trade name

**DAHT FVD**

velocity dependent device, to use in buildings and civil engineering works where requirements on individual devices are critical,

placed on the market under the name or trade mark of

**DAHT SRL**

**C.da Alezza zona PIP – 74012 Crispiano (TA) – Italy**

and produced in the manufacturing plant

**DAHT SRL – C.da Alezza zona PIP – 74012 Crispiano (TA) – Italy.**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

**EN 15129:2009**

under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

**constancy of performance of the construction product.**

This certificate was first issued on 8 July 2021 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The main characteristics of the product are reported in the Annex to this certificate.

Milan, 8 July 2021

Revision n. 0

Laboratorio Prove Materiali  
Politecnico di Milano  
Piazza Leonardo da Vinci, 32  
20133 Milano  
Tel. 02 2399 4210  
Fax 02 2399 4211  
info-lpmc-aricid@polimi.it  
www.lpmc.polimi.it

Prof. Ing. Carlo Poggi  
Head of Certification Body



**POLITECNICO**  
MILANO 1863

Laboratorio Prove Materiali - NB 1777 CPR



PRD N° 0317

**Annex to Certificate of Constancy of Performance  
no. 1777 – CPR – 21.02**

**Fluid Viscous Dampers**

with trade name

**DAHT FVD**

**product families**

DAHT FVD product families comprise fluid viscous dampers devices that provide an axial force in either tension or compression that depends on the imposed velocity only and complies with the constitutive law declared by the manufacturer over a velocity range extending at least two decades down from the maximum design level. The devices are manufactured from ferrous materials and the active surface of the piston rod is hard chromium plated. The devices are classified as Velocity Dependent, type Fluid Viscous Dampers, in accordance with Table 1 of hEN 15129:2009.

DAHT FVD devices are presented in the product families described below.

**DAHT FVD with viscous fluid A<sup>1</sup>**

Description of the product

DAHT FVD with viscous fluid A devices comprise fluid viscous dampers that provide an axial force in either tension or compression that depends on the imposed velocity only and comply with the constitutive law declared by the manufacturer over a velocity range extending at least two decades down from the maximum design level. The devices are manufactured from ferrous materials and the active surface of the piston rod is hard chromium plated. The devices are classified as Velocity Dependent, type Fluid Viscous Dampers, in accordance with Table 1 of hEN 15129:2009.

The active surfaces are in accordance with clause 7.2.3 of hEN 15129:2009. <sup>1</sup>

The viscous fluid A is in accordance with clause 7.2.4 of hEN 15129:2009. <sup>1</sup>

The temperature range is from -25° C to +50° C.

The intended use is in buildings and civil engineering works.

<sup>1</sup> appropriate documents reporting the identification characteristics of the fluid, active surfaces and outsourced manufacturing processes are deposited at the Notified Body involved in the attestation of constancy of performance procedure.





**POLITECNICO**  
MILANO 1863

Laboratorio Prove Materiali - NB 1777 CPR



PRD N° 0317

### Performance characteristics

DAHT FVD with viscous fluid A devices meet the following requirements in accordance with hEN 15129:2009:

- pressure test, clause 7.4.2.2
- low velocity test, clause 7.4.2.3
- constitutive law test, clause 7.4.2.5
- damping efficiency test, clause 7.4.2.7
- wind load cycle test, clause 7.4.2.8
- seal wear test, clause 7.4.2.9
- stroke verification test, clause 7.4.2.10

### Type, identification and use

DAHT FVD with viscous fluid A product types are evaluated on the basis of the results reported below

| DAHT FVD 250±50  |                                     |                       |            |
|--|-------------------------------------|-----------------------|------------|
| Load capacity ±250 kN  |                                     | Maximum stroke ±50 mm |            |
| Essential characteristics  | Performances                        |                       |            |
| Axial load transmission capability   | Conforming                          |                       |            |
| Durability aspects   | Conforming                          |                       |            |
|  | Parameter                           | Design value          | Unit       |
| Resistance to seismic loads/shock absorption (Survivability against repeated load cycling) | Axial force $F_d$                   | 250                   | kN         |
|  | Maximum velocity $V_d$              | 400                   | mm/s       |
|  | Seismic displacement* $d_{bd}$      | ±45                   | mm         |
|  | Constitutive law parameter C        | 101.8                 | kN(mm/s) ° |
|  | Constitutive law parameter $\alpha$ | 0.15                  | ==         |
|  | Wind load frequency $f_w$           | 1.59                  | Hz         |
|  | Wind load amplitude $d_w$           | ±5                    | Mm         |
| Rotation capability  | ==                                  | ±0.052                | rad        |
| Energy dissipation capability  | EDC                                 | 43.14                 | kJ         |
|  | Damping efficiency frequency $f_0$  | 1.414                 | Hz         |
|  | Damping efficiency amplitude $d_0$  | ±45                   | Mm         |
| Stroke   | Thermal displacement $d_{th}$       | ±10                   | mm         |
|  | Maximum displacement $d_{max}$      | ±50                   | mm         |
| ==   | Minimum service temperature $T_L$   | -25                   | ° C        |
|  | Maximum service temperature $T_U$   | +50                   | ° C        |

(\*) With reference to hEN 15129:2009, clause 7.1, DAHT FVD 250±50 is only intended to be used in buildings.

According to Test Report no. 2021/1405.

Laboratorio Prove Materiali  
Politecnico di Milano  
Piazza Leonardo da Vinci, 32  
20133 Milano  
Tel. 02 2399 4210  
Fax 02 2399 4211  
info-lpmc-aricid@polimi.it  
www.lpmc.polimi.it

Certificate of Constancy of Performance no. 1777 – CPR – 21.02 rev. 0

Annex rev. 1 of 6 March 2023

Page 2 of 7



**POLITECNICO**  
MILANO 1863

Laboratorio Prove Materiali - NB 1777 CPR



PRD N° 0317

| DAHT FVD 3000±385  |                                     |                        |                       |
|--|-------------------------------------|------------------------|-----------------------|
| Load capacity ±3000 kN   |                                     | Maximum stroke ±385 mm |                       |
| Essential characteristics  | Performances                        |                        |                       |
| Axial load transmission capability   | Conforming                          |                        |                       |
| Durability aspects   | Conforming                          |                        |                       |
|  | Parameter                           | Design value           | Unit                  |
| Resistance to seismic loads/shock absorption (Survivability against repeated load cycling) | Axial force $F_d$                   | 3000                   | kN                    |
|  | Maximum velocity $V_d$              | 400                    | mm/s                  |
|  | Seismic displacement $d_{bd}$       | ±125                   | mm                    |
|  | Constitutive law parameter C        | 1648                   | kN(mm/s) <sup>a</sup> |
|  | Constitutive law parameter $\alpha$ | 0.1                    | ==                    |
|  | Wind load frequency $f_w$           | 1.59                   | Hz                    |
|  | Wind load amplitude $d_w$           | ±5                     | Mm                    |
| Rotation capability  | ==                                  | ±0.052                 | rad                   |
| Energy dissipation capability  | EDC                                 | 1435                   | kJ                    |
|  | Damping efficiency frequency $f_0$  | 0.509                  | Hz                    |
|  | Damping efficiency amplitude $d_0$  | ±125                   | Mm                    |
| Stroke   | Thermal displacement $d_{th}$       | ±50                    | mm                    |
|  | Maximum displacement $d_{max}$      | ±385                   | mm                    |
| ==   | Minimum service temperature $T_L$   | -25                    | ° C                   |
|  | Maximum service temperature $T_U$   | +50                    | ° C                   |

According to Test Report no. 2021/1406 .





**POLITECNICO**  
MILANO 1863

Laboratorio Prove Materiali - NB 1777 CPR



PRD N° 0317

DAHT FVD with viscous fluid A types and sizes covered by the present Certificate of Constancy of Performance are manufactured in accordance with the same design and with the same parametric technical solutions.

The dimensions of the products covered by the present Certificate of Constancy of Performance can vary in the dimensional range defined below in accordance with clause 7.2.4.1 of hEN 15129.

| <i>Load Capacity</i> | <i>Maximum velocity</i> | <i>Test Report</i> |
|----------------------|-------------------------|--------------------|
| 200 to 300 kN        | up to 400 mm/s          | 2021/1405          |
| 2400 to 3600 kN      | up to 400 mm/s          | 2021/1406          |

### **DAHT FVD with viscous fluid B<sup>1</sup>**

#### Description of the product

DAHT FVD with viscous fluid B devices comprise fluid viscous dampers that provide an axial force in either tension or compression that depends on the imposed velocity only and comply with the constitutive law declared by the manufacturer over a velocity range extending at least two decades down from the maximum design level. The devices are manufactured from ferrous materials and the active surface of the piston rod is hard chromium plated. The devices are classified as Velocity Dependent, type Fluid Viscous Dampers, in accordance with Table 1 of hEN 15129:2009.

The active surfaces are in accordance with clause 7.2.3 of hEN 15129:2009. <sup>1</sup>

The viscous fluid B is in accordance with clause 7.2.4 of hEN 15129:2009. <sup>1</sup>

The temperature range is from -20° C to +40° C.

The intended use is in buildings and civil engineering works.

<sup>1</sup> appropriate documents reporting the identification characteristics of the fluid, active surfaces and outsourced manufacturing processes are deposited at the Notified Body involved in the attestation of constancy of performance procedure.

#### Performance characteristics

DAHT FVD with viscous fluid B devices meet the following requirements in accordance with hEN 15129:2009:

- pressure test, clause 7.4.2.2
- low velocity test, clause 7.4.2.3
- constitutive law test, clause 7.4.2.5
- damping efficiency test, clause 7.4.2.7
- wind load cycle test, clause 7.4.2.8
- seal wear test, clause 7.4.2.9
- stroke verification test, clause 7.4.2.10



**POLITECNICO**  
MILANO 1863

Laboratorio Prove Materiali - NB 1777 CPR



PRD N° 0317

#### Type, identification and use

DAHT FVD with viscous fluid B product types are evaluated on the basis of the results reported below

| DAHT FVD 1260±250  |   |                        |                       |
|--|---|------------------------|-----------------------|
| Load capacity ±1260 kN   |   | Maximum stroke ±250 mm |                       |
| Essential characteristics  | Performances                                |                        |                       |
| Axial load transmission capability   | Conforming                                  |                        |                       |
| Durability aspects   | Conforming                                  |                        |                       |
|  | Parameter                                   | Design value           | Unit                  |
| Resistance to seismic loads/shock absorption (Survivability against repeated load cycling) | Axial force F <sub>d</sub>                  | 1260                   | kN                    |
|  | Maximum velocity V <sub>d</sub>             | 900                    | mm/s                  |
|  | Seismic displacement d <sub>bd</sub>        | ±150                   | mm                    |
|  | Constitutive law parameter C                | 323                    | kN(mm/s) <sup>α</sup> |
|  | Constitutive law parameter α                | 0.2                    | ==                    |
|  | Wind load frequency f <sub>w</sub>          | 0.25                   | Hz                    |
|  | Wind load amplitude d <sub>w</sub>          | ±10                    | Mm                    |
| Rotation capability  | ==  | ±0.035                 | rad                   |
| Energy dissipation capability  | EDC   | 673.34                 | kJ                    |
|  | Damping efficiency frequency f <sub>0</sub> | 0.7162                 | Hz                    |
|  | Damping efficiency amplitude d <sub>0</sub> | ±150                   | Mm                    |
| Stroke   | Thermal displacement d <sub>th</sub>        | ±25                    | mm                    |
|  | Maximum displacement d <sub>max</sub>       | ±250                   | mm                    |
| ==   | Minimum service temperature T <sub>L</sub>  | -20                    | ° C                   |
|  | Maximum service temperature T <sub>U</sub>  | +40                    | ° C                   |

Laboratorio Prove Materiali  
Politecnico di Milano  
Piazza Leonardo da Vinci, 32  
20133 Milano  
Tel. 02 2399 4210  
Fax 02 2399 4211  
info-lpm-sc-aricid@polimi.it  
www.lpm-sc.polimi.it

According to Test Report no. 2023/0234 .





**POLITECNICO**  
MILANO 1863

Laboratorio Prove Materiali - NB 1777 CPR



PRD N° 0317

| DAHT FVD 180±85  |                                     |                       |            |
|--|-------------------------------------|-----------------------|------------|
| Load capacity ±180 kN  |                                     | Maximum stroke ±85 mm |            |
| Essential characteristics  | Performances                        |                       |            |
| Axial load transmission capability   | Conforming                          |                       |            |
| Durability aspects   | Conforming                          |                       |            |
|  | Parameter                           | Design value          | Unit       |
| Resistance to seismic loads/shock absorption (Survivability against repeated load cycling) | Axial force $F_d$                   | 180                   | kN         |
|  | Maximum velocity $V_d$              | 750                   | mm/s       |
|  | Seismic displacement $d_{bd}$       | ±60                   | mm         |
|  | Constitutive law parameter C        | 48                    | kN(mm/s) ° |
|  | Constitutive law parameter $\alpha$ | 0.2                   | ==         |
|  | Wind load frequency $f_w$           | 0.25                  | Hz         |
|  | Wind load amplitude $d_w$           | ±10                   | Mm         |
| Rotation capability  | ==                                  | ±0.035                | rad        |
| Energy dissipation capability  | EDC                                 | 38.48                 | kJ         |
|  | Damping efficiency frequency $f_0$  | 1.492                 | Hz         |
|  | Damping efficiency amplitude $d_0$  | ±60                   | Mm         |
| Stroke   | Thermal displacement $d_{th}$       | ±25                   | mm         |
|  | Maximum displacement $d_{max}$      | ±85                   | mm         |
| ==   | Minimum service temperature $T_L$   | -20                   | ° C        |
|  | Maximum service temperature $T_U$   | +40                   | ° C        |

According to Test Report no. 2023/0235 .



**POLITECNICO**  
MILANO 1863

Laboratorio Prove Materiali - NB 1777 CPR



PRD N° 0317

DAHT FVD with viscous fluid B types and sizes covered by the present Certificate of Constancy of Performance are manufactured in accordance with the same design and with the same parametric technical solutions.

The dimensions of the products covered by the present Certificate of Constancy of Performance can vary in the dimensional range defined below in accordance with clause 7.2.4.1 of hEN 15129.

| <i>Load Capacity</i> | <i>Maximum velocity</i> | <i>Test Report</i> |
|----------------------|-------------------------|--------------------|
| 144 to 216 kN        | up to 750 mm/s          | 2023/0235          |
| 1008 to 1512 kN      | up to 900 mm/s          | 2023/0234          |

Milan, 6 March 2023

Prof. Ing. Carlo Poggi  
Head of Certification Body  
Firmato digitalmente  
da: CARLO POGGI  
Organizzazione:  
POLITECNICO DI  
MILANO/80057930150

**The present Annex is only valid together with the  
Certificate of Constancy of Performance no. 1777 – CPR – 21.02  
rev.0 dated 8 July 2021**

**The present Annex cancels and replaces the previous Annex rev. 0  
dated 8 July 2021**

Laboratorio Prove Materiali  
Politecnico di Milano  
Piazza Leonardo da Vinci, 32  
20133 Milano  
Tel. 02 2399 4210  
Fax 02 2399 4211  
info-lpm-sc-aricid@polimi.it  
www.lpm-sc.polimi.it